

A Techno-economic assessment of the reduction of carbon dioxide emissions through the use of biomass co-combustion [☆]

D.R. McIlveen-Wright ^{a,*}, Y. Huang ^a, S. Rezvani ^a, J.D. Mondol ^a, D. Redpath ^a, M. Anderson ^a, N.J. Hewitt ^a, B.C. Williams ^b

^a School of the Built Environment, University of Ulster, Jordanstown, Newtownabbey BT37 0QB, UK

^b Biomass CHP Ltd., Blackwater Museum, N. Ireland, UK

ARTICLE INFO

Article history:

Received 27 June 2010

Received in revised form 17 August 2010

Accepted 18 August 2010

Available online 1 September 2010

Keywords:

Biomass

Co-combustion

Fluidised bed

Economic analysis

Environmental credits

ABSTRACT

Using sustainably-grown biomass as the sole fuel, or co-fired with coal, is an effective way of reducing the net CO₂ emissions from a combustion power plant. There may be a reduction in efficiency from the use of biomass, mainly as a result of its relatively high moisture content, and the system economics may also be adversely affected.

The economic cost of reducing CO₂ emissions through the replacement of coal with biomass can be identified by analysing the system when fuelled solely by biomass, solely by coal and when a coal-biomass mixture is used.

The technical feasibility of burning biomass or certain wastes with pulverised coal in utility boilers has been well established. Cofiring had also been found to have little effect on efficiency or flame stability, and pilot plant studies had shown that cofiring could reduce NO_x and SO_x emissions.

Several technologies could be applied to the co-combustion of biomass or waste and coal. The assessment studies here examine the potential for co-combustion of (a) a 600 MWe pulverised fuel (PF) power plant, (i) cofiring coal with straw and sewage sludge and (ii) using straw derived fuel gas as return fuel; (b) a 350 MWe pressurised fluidised bed combustion (PFBC) system cofiring coal with sewage sludge; (c) 250 and 125 MWe circulating fluidised bed combustion (CFBC) plants cofiring coal with straw and sewage sludge; (d) 25 MWe CFBC systems cofiring low and high sulphur content coal with straw, wood and woody matter pressed from olive stones (WPOS); and (e) 12 MWe CFBC cofiring low and high sulphur content coal with straw.

The technical, environmental and economic analysis of such technologies, using the ECLIPSE suite of process simulation software, is the subject of this study. System efficiencies for generating electricity are evaluated and compared for the different technologies and system scales. The capital costs of systems are estimated for coal-firing and also any additional costs introduced when biomass is used. The Break-even electricity selling price is calculated for each technology, taking into account the system scale and fuel used.

Since net CO₂ emissions are reduced when biomass is used, the effect of the use of biomass on the electricity selling price can be found and the premium required for emissions reduction assessed. Consideration is also given to the level of subvention required, either as a Carbon dioxide Credit or as a Renewable Credit, to make the systems using biomass competitive with those fuelled only with coal.

It would appear that a Renewable Credit (RC) is a more transparent and cost-effective mechanism to support the use of biomass in such power plants than a Carbon dioxide Credit (CC).

© 2010 Elsevier Ltd. All rights reserved.

1. Introduction

The most effective means of reducing net CO₂ emissions from coal-based power plants and among the most efficient and inexpensive uses of biomass are two complementary features of cofiring biomass with coal [1].

[☆] This paper was a presentation at the 7th European Conference on Coal Research and its Applications, Cardiff, September 2008.

* Corresponding author. Tel.: +44 028 90366808.

E-mail address: dr.mcilveen-wright@ulster.ac.uk (D.R. McIlveen-Wright).

The demand for electricity is growing steadily throughout the developed world and dramatically in the less developed countries and fossil fuels will continue to play a major role in power generation. Renewable energy sources, such as biomass or wastes, offer an attractive method of reducing greenhouse gas emissions, if they replace part or all of the fossil fuels in a power plant, and would probably be the best (cheapest and lowest risk) method for electricity generators to implement renewable energy [2], [3]. For some time the co-combustion of coal and biomass has received widespread interest as a means of conserving coal reserves and

reducing net CO₂ emissions, as reported by Hein and Bemtgen [4] and Sami et al. [5], in addition to the drive to use renewable resources, several other environmental advantages have been reported e.g. cofiring high-sulphur bituminous coal with 20% straw gave a net reduction in NO and SO₂ emissions [6]. In the EU27 Member states it has been calculated that cofiring could make up 20–35% of the estimated gap between current electricity generation from renewables and the 2010 target [7].

It is clear that there are good technical and environmental reasons for cofiring biomass with coal, but widespread implementation will depend on favourable economic factors. There have already been some attempts at examining the economics of cofiring. For example, a techno-economic analysis of the retro-fitting of coal boilers for cofiring with biomass, based on pilot plant results, has been carried out and the additional specific costs per unit of electricity generated and Mton of CO₂ emissions reduction calculated [8].

In the present paper computer simulations of a range of power plant systems were carried out and the key features are reported and compared. Details of these technologies and their technical and environmental analyses have been reported elsewhere [9], and the economic factors of the systems are examined here. In general the systems using coal solely as their fuel generate electricity more cheaply than those using biomass, or cofiring with biomass. However there are potential incentives for promoting the use of renewable energy and/or reducing carbon dioxide emissions.

Several different mechanisms for supporting renewables have been proposed, tried and often changed over time. Because of the uncertainty in energy policy concerning whether a national feed-in tariff or a tradable green certificate scheme is the more effective support mechanism for renewable energy [10], [11], [12], [13], no particular type of support is used in this paper, rather a generic support mechanism for renewables is employed. Similarly, no specific model for avoided carbon dioxide emissions has been chosen.

What has been done is to assess how much of a Renewable Credit or Carbon Credit would be necessary, regardless of the mechanism, to make each of the analysed systems competitive with large scale PF coal-fired power plants, in terms of their BEP (Break-even electricity selling price), as well as some of the smaller power generation plants.

2. Method and scope of assessment

The process simulation package, ECLIPSE [14], was used to perform techno-economic assessment studies of each technology using, initially, coal as the fuel. ECLIPSE has been successfully used to analyse a wide range of power generation systems using biomass, such as wood combustion plants [15] and fuel cells integrated with biomass gasification [16].

3. Technologies assessed

A variety of power generation technologies, a range of sizes of power plant and a number of blends of coals/biomasses/wastes as feedstocks were considered. The power generation technologies studied were pulverised fuel firing (PF), pressurised fluidised bed combustion (PFBC) and atmospheric pressure circulating fluidised bed combustion (CFBC). The power plant sizes ranged from 600 MWe for the PF plants, to 12 MWe for the smallest of the CFBC plants. A low and a high sulphur bituminous coal was used blended with straw, wood, the woody matter from pressed olive stones (WPOS) and sewage sludge. A technical and environmental assessment of the systems examined here has already been published elsewhere [17].

The analysis of these feedstocks is given in Table 1. Federal coal was taken as the standard coal in these studies. It has a relatively high sulphur content, so limestone was considered to be necessary as an absorbent for capturing 95% of the sulphur. For some of the studies a low-sulphur coal (*Bellambi*) was also assessed.

Fuel moisture contents are shown in Fig. 1.

In the 1990s coal prices remained relatively steady, but, as with other fuels, they have varied considerably since around 2004. (See Fig. 2).

Table 1
Analysis of Feedstocks Used.

Feedstock	Federal coal	Bellambi coal	Wheat straw	Wood	WPOS	Sewage sludge
Water (% ar)	6.30	6.00	14.2	33.3	13.5	4.0
Ash (% db)	6.62	13.83	4.55	0.9	10.0	21.88
HHV (MJ/kg daf)	35.64	36.18	19.90	18.73	20.89	22.94
LHV (MJ/kg daf)	34.25	35.00	18.20	17.37	19.77	21.13
<i>Ultimate analysis (% daf)</i>						
Carbon	84.0	87.6	48.84	51.0	52.06	53.92
Hydrogen	5.70	4.70	7.08	6.0	6.04	7.85
Nitrogen	1.50	1.90	1.28	0.1	3.59	5.06
Sulphur	2.60	0.80	0.16	<0.1	0.64	0.89
Chlorine	0.14	0.01	0.28	0	0	0.38
Oxygen	6.06	4.99	42.36	42.9	37.67	31.90




Fig. 1. Moisture content of fuels.




Fig. 2. Coal Prices (BP, 2008) [18].

Hence it is difficult to put a definite figure on coal prices that could be reliable over a long time period and used for power plant planning.

In order to have a reasonable estimate of fuel costs, the value of \$1.80/MMBtu (equivalent to \$1.701/GJ) for the coals, from a US DOE sponsored report [19] (DOE/NETL, 2007), published in 2007 was used. A gate fee of \$20/tonne was used for the dried sewage sludge and a notional \$5.00/GJ for the other biomass fuels.

The cost, in \$ (2008) per tonne, derived for each fuel, is shown in Fig. 3.

A total of 29 processes, as outlined in Table 3, were studied in this work.

3.1. PF combustion systems

All the studies using a PF combustion system were based upon the Amer 9 power station at Geertruidenberg in the Netherlands [20]. This is a 600 MW supercritical PF coal-fired power station with flue gas desulphurisation (FGD) [21], [22].

Four processes were based around this technology, as described in Table 3. The first process (Process Number One – PN1) was the standard process as described elsewhere [23], using the standard coal. The second process (PN2) involved replacing one level of coal burners with straw burners so that 20% of the total thermal input to the boiler could be changed from coal to chopped processed straw. No other changes were required to the process apart from balancing flows to the steam cycle and the FGD system. The third process (PN3) involved replacing one level of coal burners with sewage sludge burners so that 20% of the total thermal input to the boiler could be changed from coal to dried sewage sludge cake. Again no other changes were required to the process apart from balancing flows to the steam cycle and the FGD system.

The fourth process (PN4) was based on the use of fuel gas from a straw gasifier as a reburn fuel. Reburn technologies achieves a NO_x




Fig. 3. Cost of fuel.

Table 2

Superheated Steam Conditions for the CFBC Systems.

Plant Size (MWe)	Pressure (bar)	Temperature (°C)	Reheat
12	80	480	None
25	92	495	None
125	160	538	Reheat to 538 °C
250	160	538	Reheat to 538 °C

Table 3

Technical and environmental indicators for all systems assessed.

Process number	Technology, fuel	Efficiency (%)	Total CO ₂ (g/kWh)*	Net CO ₂ (g/kWh)**
PN1	600 MWe PF, 100% Federal coal	44.0	759	759
PN2	600 MWe PF, 20% straw	43.8	773	610
PN3	600 MWe PF, 20% sewage sludge	43.8	765	765
PN4	600 MWe PF, 20% Straw (reburn)	43.2	818	625
PN5	350 MWe PFBC, 100% federal coal	41.2	783	783
PN6	350 MWe PFBC, 20% sewage sludge	41.1	792	634
PN7	250 MWe CFBC, 100% federal coal	39.0	841	841
PN8	250 MWe CFBC, 20% straw	38.7	858	678
PN9	250 MWe CFBC, 20% sewage sludge	39.0	866	866
PN10	125 MWe CFBC, 100% federal coal	39.0	841	841
PN11	125 MWe CFBC, 20% straw	38.7	859	678
PN12	25 MWe CFBC, federal coal only	30.2	1107	1107
PN13	25 MWe CFBC, federal coal + 50% straw	29.5	1163	558
PN14	25 MWe CFBC, federal coal + 50% wood	28.2	1266	552
PN15	25 MWe CFBC, federal coal + 50% WPOS	29.2	1172	580
PN16	25 MWe CFBC, Bellambi coal only	30.2	1095	1095
PN17	25 MWe CFBC, Bellambi coal + 50% straw	29.6	1157	550
PN18	25 MWe CFBC, Bellambi coal + 50% wood	28.2	1259	543
PN19	25 MWe CFBC, Bellambi coal + 50% WPOS	29.2	1166	566
PN20	25 MWe CFBC, wood only	26.5	1433	0
PN21	25 MWe CFBC, straw only	29.1	1213	0
PN22	12 MWe CFBC, Federal Coal Only	29.5	1132	1132
PN23	12 MWe CFBC, federal coal + 50% straw	28.9	1192	600
PN24	12 MWe CFBC, Bellambi Coal Only	29.5	1120	1120
PN25	12 MWe CFBC, Bellambi coal + 50% straw	28.8	1182	590
NP1	25 MWe CFBC, 100% WPOS	28.5	1228	0
NP2	12 MWe CFBC, 100% wood	26.3	1443	0
NP3	12 MWe CFBC, federal coal + 50% wood	27.5	1296	575
NP4	12 MWe CFBC, 100% straw	28.4	1242	0

* Total CO₂ refers to the gross emissions of CO₂ from this power plant.

** Net CO₂ refers to the emissions of CO₂ from the fossil fuel used in this power plant, since biomass is assumed to be CO₂ neutral. Gross CO₂ and net CO₂ will be the same where only fossil fuel is used.

emission reduction of about 50% by staging the combustion within the furnace [24], [25].

3.2. PFBC Combustion Systems

The first of the two PFBC systems uses only the standard coal (PN5) whereas the second system (PN6) is co-combusted with a mixture of 80% standard coal and 20% dried sewage sludge. Both

are based on the 350 MW Karita New Power Station Number One system [26], [27].

3.3. CFBC combustion systems

Twenty-three assessment studies were based on the CFBC systems, as tabulated in Table 3. The 125 and 250 MW CFBCs were based on the Gardanne power plant [28], [29] and the 25 and 12 MW CFBCs based on Midkraft's 78 MWth CFBC power plant at Grenaa in Denmark.

The superheated steam inlet conditions at the high-pressure steam turbine for the different processes are given in Table 2. The system technologies are described more fully elsewhere [30].

4. Technical results

A full appraisal of the technical, and environmental features of these systems has been described elsewhere [31], but only certain key indicators of performance are needed to assess the effects of using biomass or wastes on CO₂ emissions reduction.

The indicator of technical performance is taken to be the LHV Net Electrical Efficiency (Efficiency, %). The CO₂ emission level is taken as a measure of the environmental performance (total CO₂). Where biomass is used as the fuel, the CO₂ released by the biomass may be offset from the total CO₂ emissions (net CO₂), assuming that it has been sustainably grown [32].

5. Economic results

5.1. Method of assessment

A full economic analysis was carried out for all systems using the ECLIPSE process simulation package.

The TCI (Total Capital Investment) is the total capital investment of building the power station, starting from a "green field" site, including the normal infrastructure that would be contained within the boundary fence, i.e. roads, offices, control rooms, services, utilities, etc. Added to this is an allowance for the working capital, capital fees and contingency. There is no allowance for additional capital cost for "first-of-its kind" costs and no costs due to the additional risks incurred with financing the construction of a novel, prototype or demonstration plant. A Northern European location is assumed for the plant, with similar construction costs to the UK.

The calculation of the SCI (Specific Capital Investment) requires a value for the electricity production, or electricity sent out. The electricity sent out is the gross power generated by the power station, less the power required by all the auxiliaries on-site and less the losses from the on-site transformers. It assumes that the power station operates at design load for the defined plant occupancy; no allowance is made for part load operation. The calculation of the electricity sent out is performed using a consistent set of environmental conditions, such as ambient air and cooling water conditions.

The BESP is the price that the generator must charge for the electricity that is sent out to the grid in order that, over the lifetime of the station, its net present worth is zero. In other words, the present day value of the net income is equal to present day value of the capital investment. The present day value of the net income is the sum of the net annual income over the lifetime of the plant, discounted back to the present day value, using a given discounted cash flow rate. The present day is taken as the first day that the commissioned power station starts operation. The net annual income includes the income from selling the electricity produced and any other valuable by-products as well as the cost of fuel,

raw materials, services (water, effluent, and solids disposal), operating and maintenance labour and supplies, and insurance. The net annual income is of course affected by the occupancy of the power station. The present day value of the capital investment is the TCI (Total Capital Investment) appreciated over the construction and commissioning times of the plant using the given discounted cash flow rate. No allowance is made for inflation, payment of taxes or profit, except as is allowed for setting a value for the discounted cash flow rate.

The typical values for the capital and operating cost indices and factors large and small power stations are given below (See Table 4).

These analyses are too detailed to show here, but certain indicators have been selected. The economic indicators for a system are taken to be: (a) the Total Capital Investment (TCI) in \$M (2008); (b) Specific Capital Investment (SCI or SI) i.e. Capital Investment (in 2008 \$) per Installed Net kW_e; and (c) the Break-even Electricity Selling Price (BESP) in \$/MWh.

Whilst every effort is made to validate the capital cost estimation data, using published information and actual quotations from equipment vendors, the absolute accuracy of this type of capital cost estimation procedure has been estimated at about ±25–30%. However, although the absolute accuracy of a single cost estimate may be only ±25–30%, what has been done in these studies is to compare families of similar technologies, composed of similar types of equipment. Therefore, the comparative capital cost estimates, which are based on the accurate calculation of a difference in a basic design by the mass and energy balance program, should be valid.

5.2. Calculated values for specific investment

The specific capital investment (SCI or SI) for the supercritical PF system with FGD, fired by coal only (system PN1), was found to be \$1453/kW_e and the Break-even Electricity Selling Price to be \$53.5/MWh. This corresponds well with a report (DOE/NETL, 2007) for the US DOE, which found the SI for such plants to be \$1562/kW_e and the BESP to be \$66/MWh on average [33] and validates the ECLIPSE economic analysis to some extent.

5.3. Calculated BESP values

The calculated Break-even Electricity Selling Prices for the large and small scale systems are shown in Figs. 6 and 7 respectively.

6. Support mechanisms

In many countries financial mechanisms have been advocated or introduced to support the use of renewables or to reduce CO₂ emissions in recent years.

These mechanisms will not be detailed in this paper as they tend to be changed frequently. However, the level of support

Table 4
Typical Economic indices for large and small systems.

Economic indices and factors	Power station > 100 MWe	Power station < 100 MWe
Construction time (years)	4	2
Commissioning time (years)	0	0
DCFR (%)	7.5	7.5
Capital fees (%TCI)	2	2
Working capital (%TCI)	2	2
Contingency (%TCI)	10	10
Plant occupancy (%) (1st Year, 2nd, Rest)	40/60/85	60/85/85
Plant life (years)	25	25
Operating cost (%TCI)	1.1	1.1
Maintenance cost (%TCI)	2.3	2.3
Insurance cost (%TCI)	2.0	2.0

needed to make the biomass or co-fired systems competitive with coal-fired systems is calculated and assessed. Two types of support are discussed; a Renewables support, which is based on overcoming the increased cost of electricity for biomass and co-fired systems (in comparison with coal-fired systems) in \$/MWh and a Support for CO₂ Emissions Avoided/Reduction in \$/tonne of CO₂. For simplicity these will be known as a Renewable Credit (RC) and a Carbon Credit (CC) respectively in this paper.

Support mechanisms also exist for the reduction of SO_x and NO_x emissions, which could be available for biomass cofiring or combustion, but these are not considered in this paper, although they could well have an impact on the power plant economics.

6.1. Carbon credit

6.1.1. The effect on economics of biomass co-combustion systems of CO₂ emissions reduction

As can be seen from the Tables 3 and 5 (and Figs. 4–7), co-combustion of biomass with coal has a negative impact on the efficiency, specific capital investment (SI) and electricity generation cost (BESP) of all of the systems. However, there was a concomitant reduction in net CO₂ emissions resulting from the biomass cofiring. It is generally accepted that some form of support should be given to support the benefits arising from biomass cofiring.

One way of comparing the economic performance of the different biomass co-combustion systems is to offset the increase in

Break-even Electricity Selling Price, due to using biomass instead of coal, with the reduction in CO₂ emissions achieved by this displacement. This is the simple form of Carbon Credit (CC) that is used here. These figures are presented in Table 6 and Fig. 8. Fig. 8 shows the subventions (CC and BESP increase) needed to make each system competitive with the 25 MWe CFBC plant fuelled solely by coal (PN12).

Note: Renewable Credit is not the same as BESP increase, since the increase in BESP would be applied to all units of electricity

Table 5
Economic indicators for all systems.

Process number	Technology, fuel	TCI*	SCI**	BESP***
PN1	600 MWe PF, 100% Federal Coal	874	1453	53.5
PN2	600 MWe PF, 20% Straw	908	1512	63.5
PN3	600 MWe PF, 20% Sewage Sludge	888	1480	0.0
PN4	600 MWe PF, 20% Straw (reburn)	1034	1726	67.4
PN5	350 MWe PFBC, 100% Federal Coal	602	1670	62.6
PN6	350 MWe PFBC, 20% Sewage Sludge	625	1784	0.0
PN7	250 MWe CFBC, 100% Federal Coal	460	1840	68.9
PN8	250 MWe CFBC, 20% Straw	480	1921	76.7
PN9	250 MWe CFBC, 20% Sewage Sludge	475	1897	0.0
PN10	125 MWe CFBC, 100% Federal Coal	283	2267	110.9
PN11	125 MWe CFBC, 20% Straw	299	2390	114.2
PN12	25 MWe CFBC, Federal Coal Only	70	2784	95.9
PN13	25 MWe CFBC, Federal Coal + 50% Straw	78	3124	107.7
PN14	25 MWe CFBC, Federal Coal + 50% Wood	73	2920	130.0
PN15	25 MWe CFBC, Federal Coal + 50% WPOS	71	2852	115.6
PN16	25 MWe CFBC, Bellambi Coal Only	68	2716	90.8
PN17	25 MWe CFBC, Bellambi Coal + 50% Straw	78	3124	119.6
PN18	25 MWe CFBC, Bellambi Coal + 50% Wood	73	2920	128.7
PN19	25 MWe CFBC, Bellambi Coal + 50% WPOS	71	2852	114.2
PN20	25 MWe CFBC, Wood Only	76	3056	164.5
PN21	25 MWe CFBC, Straw Only	83	3328	142.9
PN22	12 MWe CFBC, Federal Coal Only	41	3230	108.8
PN23	12 MWe CFBC, Federal Coal + 50% Straw	48	3770	140.1
PN24	12 MWe CFBC, Bellambi Coal Only	41	3230	105.7
PN25	12 MWe CFBC, Bellambi Coal + 50% Straw	48	3770	138.6
NP1	25 MWe CFBC, 100% WPOS	71	2852	133.6
NP2	12 MWe CFBC, 100% Wood	44	3460	148.9
NP3	12 MWe CFBC, Federal Coal + 50% Wood	45	3548	132.5
NP4	12 MWe CFBC, 100% Straw	42	3341	147.2

* TCI means Total Capital Investment.
 ** SCI means Specific Capital Investment.
 *** BESP means Break-even Electricity Selling Price.




Fig. 4. Specific Investment of large scale systems.




Fig. 5. Specific Investment for 25 MW CFBCs.




Fig. 6. Break-even electricity Selling Price for the large systems.




Fig. 7. Break-even electricity Selling Price for the 25 MWe CFBC systems.




Fig. 8. The BESP increase due to cofiring or firing with biomass and the CO2 credit required to nullify this increase in BESP in the 25 MWe CFBCs.




Fig. 9. A comparison of the increase in BESP and reduction in net CO₂ emissions for 25 MW CFBCs compared to the large scale PF system using 100% (Federal) coal.

generated by a co-combustion system, whereas it is assumed here that the RC would only be paid for the units generated from biomass.

For small-scale combustion of wood (PN20) to compete with large-scale production of electricity for sale on the open market (e.g., compared with PN1, the 600 MW supercritical PF plant) a carbon credit of 146.2 \$/tonne of CO₂ emission avoided is required.

When comparing the other 25 MWe CFBC systems with the “coal only” (PN12) version, the carbon credit required for 50% wood co-combustion (PN14) is very similar to direct combustion (PN20), it increases slightly from 61.4 to 62.0 \$/tonne CO₂ avoided. Therefore to encourage small industrial scale CFBC combustion of wood, or co-combustion of coal with wood, a credit of about 62 \$/tonne CO₂ avoided would be required. WPOS requires lower credit of about 37 \$/tonne of CO₂ emission avoided to encourage its use.

In Fig. 10 co-combustion of straw with coal in large PF and CFBC power plants is compared with large scale PF (PN1). Co-combustion of straw with coal in either a PF boiler system (PN2) or a large scale CFBC system (PN8) require a credit of 67.1 and 47.9 \$, respectively is required for each tonne of CO₂ avoided.

6.2. Renewable credit

The Renewable Credit would be used to compensate for the increase in the cost of electricity generation (per kWh or MWh) for using biomass. Since it is assumed that the Renewable Credit would only be paid on units of electricity generated from Renewables i.e. biomass, then the value of the RC per MWh is given by:

$$RC = \text{BESP Increase} / \text{Percentage of cofired biomass}$$

Here it is also used to assess the effect of moving from 600 MW PF power plants to smaller (250 MW) and much smaller (25 and 12 MW) CFBCs.

Table 6
Carbon Credit and Renewable Credit for using biomass in the 25 MW CFBCs (as compared with 25 MWe CFBC).

Co-combustion system	PN13	PN14	PN15	PN20	PN21	NP1
% Biomass	50	50	50	100	100	100
Biomass type	Straw	Wood	WPOS	Wood	Straw	WPOS
System compared with	PN12	PN12	PN12	PN12	PN12	PN12
Increase in BESP (\$/MWh)	11.8	34.1	19.7	68.6	47.0	37.7
RC (\$/MWh)	23.6	68.2	39.4	68.6	47.0	37.7
Reduction in CO ₂ missions (g/kWh)	549	555	535	1107	1107	1107
CC, Cost \$/t CO ₂	21.5	61.4	37.4	62.0	42.5	34.1

6.3. RCs and large systems

Fig 10 shows that an increase in BESP of 10.0 \$/MWh would compensate for using 20% straw in a PF power plant and 7.8 \$/MWh in a 250 MW CFBC, corresponding to an RC value of 50 and 39 \$/MWh, respectively. However, if we compare with the PF power plant (PN1), from Table 5 it can be seen that there is an increase in BESP of (76.7–53.5) 23.2 \$/MWh, which corresponds to an RC of 116 \$/MWh in order to compensate for using 20% straw in a 250 MW CFBC (PN8) instead of coal-firing a 600 MW PF power plant. This difference is principally due to the drop in efficiency between the 600 MW PF and the 250 MW CFBC (see Table 3) from 44% to 38.7%, rather than due to the use of biomass.

6.4. RCs and 25 MW CFBCs

From Fig 8 and Table 6, it can be seen that around 70 \$/MWh would compensate for 50% cofiring of wood, or 100% wood firing; and around 40 \$/MWh would suffice for WPOS firing or cofiring, when compared with the 25 MW 100% coal fuelled CFBC.




Fig. 10. CO₂ Credit required to offset increase in BESP for large systems.

If these 25 MW CFBCs are compared with PN1 – the 600 MW PF power plant (using coal only), then an RC of between 110 and 150 \$/MWh would be needed for the 50% cofired 25 MW CFBCs and between 80 and 110 \$/MWh for the 100% biomass-fuelled CFBCs (see Table 7 and Fig. 9).

6.5. RCs and 12 MW CFBCs

If we consider the smaller 12 MW CFBCs and compare them to PN1, then an RC of 160 – 185 \$/MWh would be needed to make the 50% cofired 12 MW CFBCs competitive and around 95 \$/MWh for the 100% biomass systems (see Table 8 and Fig. 11).

6.6. RC compared with CC

If the overall income for RCs and for CCs is calculated for a year, assuming an 85% plant occupancy, it can be seen from Table 9 that the RC is consistently less than the CC. This implies that it would cost the taxpayer less to make cofiring competitive through the RC support mechanism than with the CC. However, the CC itself is based on certain assumptions, and evaluating it is not straightforward.

Table 9 shows how much the CC and RC payments would need to be in order to compete economically with PN1, the 600 MW supercritical PF power plant.

It is clear from the table that, for all the different power plants and co-combustion scenarios, the CC costs per annum are greater than RC costs. RCs have also other advantages over CCs since they

Table 7

A comparison of the increase in BESP, RC and CC for 25 MW CFBCs compared to the large scale PF system using 100% (Federal) coal.

Co-combustion system	PN12	PN13	PN14	PN15	PN20	PN21	NP1
% Biomass	0	50	50	50	100	100	100
Biomass Type	0	Straw	Wood	WPOS	Wood	Straw	WPOS
System compared with	PN1	PN1	PN1	PN1	PN1	PN1	PN1
Increase in BESP (\$/MWh)	42.4	54.2	76.5	62.1	111	89.4	80.1
RC (\$/MWh)		108.4	153	124.2	111	89.4	80.1
Reduction in CO ₂ emissions (g/kWh)		201	207	179	759	759	759
CC, Cost \$/t CO ₂		269.7	369.6	346.9	146.2	117.8	105.5

Table 8

A comparison of the increase in BESP and reduction in net CO₂ emissions for 12 MW CFBCs compared to the large scale PF system using 100% (Federal) coal.

Co-combustion system	PN22	PN23	PN24	PN25	NP2	NP3	NP4
% Biomass	0	50	0	50	100	50	100
Biomass type	0	Straw	0	Straw	Wood	Wood	Straw
System compared with	PN1	PN1	PN1	PN1	PN1	PN1	PN1
Increase in BESP (\$/MWh)	55.3	86.6	52.2	85.1	95.4	79	93.7
RC (\$/MWh)		173.2		170.2	95.4	158	93.7
Reduction in CO ₂ Emissions (g/kWh)		159		169		184	
Cost \$/t CO ₂		531.4		491.1		417.9	

Note: PN24 and PN25 used Bellambi coal, the others used Federal coal.




Fig. 11. A comparison of the increase in BESP and reduction in net CO₂ emissions for 12 MW CFBCs compared to the large scale PF system using 100% (Federal) coal.

would be more easily calculated, monitored, traded and less vulnerable to world market fluctuations.

The RC is probably a more transparent support mechanism for biomass combustion and cofiring than the CC, since it does not rely on assuming the carbon neutrality of the biomass, which is really only an attribute of an energy crop, or involve a life cycle analysis (LCA) of the power plant with the fuel production within the system boundaries [34]. Wheat straw, and WPOS are not energy crops, but agricultural wastes. However, if they were left to rot in the fields, their greenhouse potential as methane emissions would be greater than if they were combusted [35]. For simplicity, the net CO₂ emissions for wheat straw, WPOS and dried sewage sludge have been calculated in the same way as for energy crops, but the validity of such a method may not always be applicable.

7. Conclusions

Clearly there are many difficulties in comparing biomass combustion at small scale with biomass/coal cofiring in large and small power plants or with systems fuelled only by coal. Problems would occur in any case if the technical and economic properties of different technologies at widely different scales are compared, even if they are using the same fuel [36].

Generic Renewable Credit (RC) and Carbon Credit (CC) systems have been explored here and estimates of their respective values for competitiveness with supercritical PF systems made. The RC method would appear to be preferable.

Table 9

The possible RC or CC payments needed to make cofiring economically equivalent to coal combustion only (PN1).

Process number	BESP increase [*]	CO ₂ cost	Electricity generated at 85% occupancy	Renewable units	Total RC required	RC per renewable unit only ^{**}	Net CO ₂	CC required	CC-RC
	\$/MWh	\$/tonne	MWh/a	MWh/a	\$ m/a	\$/MWh	ktonnes/a	\$ m/a	\$ m/a
PN1			44,67,600	0					
PN2	10	67.1	44,67,600	893,520	44.7	50	2725	182.9	138.2
PN8	23.2	286.4	18,47,092	369,418	42.9	116	1252	358.7	315.8
PN11	60.7	749.4	932,053	186,411	56.6	303.5	632	473.6	417.0
PN13	54.2	269.7	175,420	87,710	9.5	108.4	98	26.4	16.9
PN14	76.5	369.6	167,505	83,753	12.8	153	92	34.2	21.4
PN15	62.1	346.9	173,447	86,724	10.8	124.2	101	34.9	24.1
PN17	66.1	316.3	176,038	88,019	11.6	132.2	97	30.6	19.0
PN18	75.2	348.1	168,116	84,058	12.6	150.4	91	31.8	19.1
PN19	60.7	314.5	174,028	87,014	10.6	121.4	98.5	31.0	20.4
PN23	86.6	544.7	91,936	45,968	8.0	173.2	55	30.0	22.1
PN25	85.1	503.6	92,613	46,307	7.9	170.2	55	27.5	19.6
NP3	79	429.3	87,945	43,972	6.9	158	51	21.7	14.8

^{*} Relative to process PN1 (large scale supercritical PF coal system).^{**} Where RC is given just for the percentage of electricity generated from biomass, not all electricity generated.

In the three large scale technologies reviewed here, there is little reduction in efficiency incurred through cofiring even 20% straw or dried sewage sludge with coal and the values of RC and CC required to promote cofiring over “coal only” are relatively small.

For the “small” 12 and 25 MWe CFBCs an efficiency penalty for using biomass, mainly due to the corresponding moisture content of the respective type of biomass, must be endured. When the CFBC is solely or 50% fuelled by biomass, separate diminution handling and feeding requirements may be necessary, leading to additional capital costs and higher electricity generation prices. Compared with the same scale of CFBC (25 MWe) using only coal, a CC from 20 to 65 \$/tonne CO₂ and an RC between 25 and 70 \$/MWh would be required. (The higher values corresponded to systems using wood, which had the highest moisture content of the biomass types investigated).

When the small CFBCs are compared with the large PF reference plant (PN1), relatively large values of CC and RC would be required, but some of this can be attributed to economies of scale and the comparatively lower efficiencies of any small-scale combustion power plant.

References

- [1] Baxter L. Biomass-coal co-combustion: opportunity for affordable renewable energy. *Fuel* 2005;84:1295–302.
- [2] Baxter L (op.cit., 2005).
- [3] Baxter L, Koppejan J. Co-combustion of biomass and coal. *Euroheat and Power (English Edition)* 2004;1:34–9.
- [4] Hein KRG, Bemtgen JM. EU clean coal technology-co-combustion of coal and biomass. *Fuel Process Technol* 1998;54:159–69.
- [5] Sami M, Annamalai K, Wooldridge M. Co-firing of coal and biomass fuel blends. *Prog Energy Combust Sci* 2001;27:171–214.
- [6] Pedersen LS, Nielsen HP, Kiil S, Hansen LA, Dam-Johansen K, Kildsig F, et al. Full scale co-firing of straw and coal. *Fuel* 1996;75:1584–90.
- [7] Hansson J, Berndes G, Johnsson F, Kjarstad J. Cofiring biomass with coal for electricity generation – an assessment of the potential in EU27. *Energy Policy* 2009;37(4):1444–55.
- [8] De S, Assadi M. Impact of Cofiring biomass with coal in power plants – A techno-economic assessment. *Biomass and Bioenergy* 2009;33:283–93.
- [9] McIlveen-Wright DR, Huang Y, Rezvani S, Wang Y. A technical and environmental analysis of co-combustion of coal and biomass in fluidised bed technologies. *Fuel* 2007;86:2032–42.
- [10] Fouquet D, Johansson TB. European renewable energy policy at crossroads – focus on electricity support mechanisms. *Energy policy* 2008;36(11):4079–92.
- [11] Toke D. The EU Renewables Directive – what is the fuss about trading. *Energy Policy* 2008;36(8):3001–8.
- [12] Jacobsson S, Bergek A, Finon D, Lauber V, Mitchell C, Toke D, et al. EU renewable energy support policy: faith or facts? *Energy Policy* 2009;37(6):2143–6.
- [13] Bertoldi P, Huld T. Tradable certificates for renewable electricity and energy savings. *Energy Policy* 2006;34(2):212–22.
- [14] Williams BC, McMullan JT. Development of computer models for the simulation of coal liquefaction processes. In: Imariso G, Bemtgen JM, editors. *Progress in Synthetic Fuels*. London: Graham and Trotman; 1988. p. 183–9.
- [15] McIlveen-Wright DR, Williams BC, McMullan JT. A reappraisal of wood-fired combustion. *Bioresour Technol* 2000;76(3):183–90.
- [16] McIlveen-Wright DR, Guiney DJ. Wood-fired fuel cells in an isolated community. *J Power Sources* 2002;106(1–2):93–101.
- [17] McIlveen-Wright et al., (2007), op. cit.
- [18] BP (2008), “BP Statistical Review of World Energy”, <http://www.bp.com/sectiongenericarticle.do?categoryId=9023787&contentId=7044845> (accessed on 1st May 2009).
- [19] DOE/NETL, (2007) “cost and performance baseline for fossil energy plants”, DOE/NETL-2007/1281, Volume 1: Bituminous Coal and Natural Gas to Electricity, http://www.netl.doe.gov/energy-analyses/pubs/Bituminous%20Baseline_Final%20Report.pdf, (accessed 4th May 2009).
- [20] EPZ Reports. “The 600 MW Supercritical Monotube Steam Generator Amer 9” and “Amercentrale Eenheid 9, Technische Gegevens”. c1988.
- [21] Gramelt S, Deutsche Babcock Anlagen GmbH. “FGD System for 600 MWe Coal Fired Power Plant – Process Description, PFD, Mass and Energy Balance, Equipment Specifications”. Private Communication 1994.
- [22] Breihofer D, Mielenz A, Rentz O. “Emission Control of SO₂, NO_x and VOC at Stationary Sources in the Federal Republic of Germany” Karlsruhe, 1991.
- [23] EPZ Reports, (1998), op.cit. and McIlveen-Wright et al., (2007), op. cit.
- [24] Rudiger H, Kicherer A, Graul U, Spliethoff H, Klein K. Investigations in combined combustion of biomass and coal in power plant technology. *Energy and Fuels* 1996;10:789–96.
- [25] Kicherer A, Spliethoff H, Maier H, Hein K. The Effect of different reburning fuels on NO_x reduction. *Fuel* 1994;73(9):1443–7.
- [26] Asai A, Azaki K, et al. System outline and operational status of Karita Power Station New Unit 1 (PFBC). *JSME Int J, Ser B: Fluids and Thermal Engineering* 2004;47:193–9.
- [27] Operational Problems, Trace Emissions and By-Product Management for Industrial Biomass Co-Combustion. Contract No. JOR3-CT95-0057 – OPTEB, Joule-Thermie programme of the European Commission, (1998), op.cit. and McIlveen-Wright et al., (2007), op. cit.
- [28] Rajaram S. Next generation CFBC. *Chemical Engineering Science* 1999;54:5565–71.
- [29] Jacquet L, Jaud J, Ratti G, Klinger JP. Scaling up of CFB boilers the 250 MWe GARDANNE CFB project. *Proceedings of the American Power Conference* 1994;56:930–6.
- [30] McIlveen-Wright DR, Huang Y, Rezvani S, Wang Y. A technical and environmental analysis of co-combustion of coal and biomass in fluidised bed technologies. *Fuel* 2007;86:2032–42.
- [31] McIlveen-Wright et al., (2007), op.cit.
- [32] Baxter (2005), op.cit.
- [33] “Cost and Performance Baseline for Fossil Energy Plants”, DOE/NETL-2007/1281 Volume 1: Bituminous Coal and Natural Gas to Electricity, Final Report (Original Issue Date, May 2007), Revision 1, August 2007. National Energy Technology Laboratory www.netl.doe.gov.
- [34] Heller MC, Keoleian GA, Mann MK, Volk TA. Life cycle energy and environmental benefits of generating electricity from willow biomass. *Renewable Energy* 2004;29(7):1023–42.
- [35] Hughes E. Biomass cofiring: economics, policy and opportunities. *Biomass and Bioenergy* 2000;19:457–65.
- [36] Hughes, 2000, op. cit.